


Homeowner Heating Check Up- Winter



1. Replace air filter:



Recommended once a month

2. Open the value dampers



Restriction of airflow could convey to a furnace overheating.
In case of a heat pump, it would raise pressure and can damage the compressor

3. Make sure registers are open and return grills are not obstructed.




To ensure proper airflow thru the equipment.

4. Make sure CO detectors are operational.





Double check the lifetime of these devices in the manufacture specs.

5. Check thermostat and make sure house is heating.



7. Finally.....



Contact us at 703-955-9408

Stay warm and enjoy the winter.